4150-01



- Installs in **SECONDS!**
- Made STRONG
- REUSABLE!
- **EASY** Install
- 8 FOOT Drain Line
- 360° Coverage
- Prevents Overspray\*

Fits Systems Up To 12,000 BTU

\*NOTE: The Clean Guard does not cover exposed electronics. Please be sure to protect any electronics when cleaning with a cleaner and when pressurized water is required.

**Use with these Nu-Calgon Products:** 



Nu-Calgon 2611 Schuetz Road St. Louis, M0 63043 Customer Service: 800-554-5499 Chemical Emergency: 800-424-9300 www.nucalgon.com (1018) Calgon is a licensed trade name.

Made in Panama.



## **Directions For Use:**

This product must be used in accordance to following directions by HVACR professionals only.

Ensure You Have Proper Supplies Before You Start: The Clean Guard (4150-01) is sized for wall mounted mini-split indoor coils up to 12,000 BTU (one ton) in size. Ensure it is the correct product for the system. For wall mounted mini-split indoor coils between 18,000 and 36,000 BTU (1.5 to 3 tons) in size, it will require larger Clean Guard XL (4150-02). The Clean Guard will also require the use of a readily available five gallon bucket, Nu-Calgon coil cleaner and Turbo Tank pressure sprayer (or other market option).

- 1. Disconnect power from the unit.
- 2. Remove the return filters and protective cover off the mini-split indoor unit.
- 3. Simply open up the bag, center it on mini-split and tighten adequately around unit with the plastic wheel lock. **Important:** Make sure the elastic band has been tightened and adjusted so there is a good fit around the unit to create a workable seal around the unit so as not to cause damage with responsible use of Nu-Calgon coil cleaners when cleaning the coil/blower followed by a power water wash if necessary.
- 4. <u>IMPORTANT</u>: The Clean Guard does not cover exposed electronics. Please be sure to protect any electronics when cleaning with a cleaner and when pressurized water is used.
- 5. Position the five gallon bucket on a stable surface, typically the floor in most cases and position the Clean Guard funnel into the bucket.
- 6. During cleaning, wear protective gloves and eyewear.
- 7. Select a Nu-Calgon coil cleaner that best suited for the job. For coils and blowers that need to be cleaned and disinfected, Nu-Calgon's Evap-Fresh gallon (4166-08) with the use of 50P Sprayer (4770-0) or Evap-Fresh No Rinse aerosol (4166-75) with the use of the Talon Flexible Wand (4776-0) are good options. For tough duty, Tri-Pow'r aerosol (4371-75) is a good choice.
- 8. Rinse with Nu-Calgon's Turbo Tank pressure sprayer (available 2019) or other readily available market option.
- 9. While cleaning, keep an eye on the five gallon bucket to cleaner/water is draining into bucket properly; resolve any kinks in the Clean Guard as necessary.
- 10. When done cleaning, keep Clean Guard bag on unit until dripping stops. An alternate method is to hold the bag shut, briefly turning on the unit for the blower to quickly discharge water into bag before removing bag.
- 11. Remove Clean Guard and recommission the mini-split back to service.
- 12. Rinse, dry and store the Clean Guard inside the bucket for repeated use.

## **Limited Warranty**

Nu-Calgon warrants this item from defects in material and workmanship. Nu-Calgon will replace once proven upon examination to be defective. This warranty is valid for 30 days from date of the original purchase. This warranty excludes unusual wear, abuse, unreasonable use or damage from an accident. Contact your local Nu-Calgon authorized wholesaler for further assistance.