

4720-14

 Nu-Calgon



Installation Date:

Check the pH level at the outlet annually. The neutralization media should be replaced when the pH drops below the minimum level of the local water authority. For replacement media (p/n: 4720-15), contact your local Nu-Calgon wholesaler.

⚠ WARNING: This product can expose you to Silica, crystalline, which is known to the State of California to cause cancer. For more information go to www.P65Warnings.ca.gov.

Made in Canada. • 2611 Schuetz Rd. • St. Louis, MO. 63043 • www.nucalgon.com • CALGON is a licensed trade name. (1124)